

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

SIEMENS SAN.VE TIC.A.S., ADV D EU TR MI&C

Yakacik Caddesi No: 111 Kartal

34870 Istanbul, Türkiye

Reference Implementation

The tested device is a reference implementation of a Technology Component. Any device using this implementation still needs to be certified with their own VendorID, DeviceID and GSD file.

the Certificate No: **Z13084** for the PROFINET Device:

Model Name: ERTEC 200P Evaluation Kit

Revision: 6ES7195-3BE00-0YA1; SW/FW: V5.1.0; HW: 3

Identnumber: 0x002A; 0x0008

GSD: GSDML-V2.43-Siemens-ERTEC200pEvalkit-20230301.xml

DAP: DAP 1, 0x00000001

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/> PNIO_Version	V2.43
<input checked="" type="checkbox"/> Conformance Class	C
<input checked="" type="checkbox"/> Optional Features	Legacy, MRP, FSU, Dynamic Reconfiguration, System Redundancy S2
<input checked="" type="checkbox"/> Application Class(es)	HighPerformance, Isochronous, High Availability
<input checked="" type="checkbox"/> Netload Class	III
<input checked="" type="checkbox"/> PNIO_Tester_Version	Version 2.43.1.2 with annex spirta
<input checked="" type="checkbox"/> Tester	an testlabs, Prague, Czech Republic; PN 023-04

This certificate is granted according to the document:

“Framework for testing and certification of PROFIBUS and PROFINET products”.

For all products that are placed in circulation by **April 21, 2026** the certificate is valid for life.

Karlsruhe, May 25, 2023

Board of PROFIBUS Nutzerorganisation e. V.



(Official in Charge)




(Xaver Schmidt)



(Frank Moritz)