

# Certificate

PROFIBUS Nutzerorganisation e.V. grants to

## SICK AG

Erwin-Sick-Str. 1, 79183 Waldkirch, Germany

the Certificate No: **Z11926** for the PROFINET Device:

Model Name: MICS3-xxAxxxPx  
 Revision: SW/FW: R1.85.0; HW: 10300  
 Identnumber: 0x0101; 0x2202  
 GSD: GSDML-V2.41-SICK-microScan3-20250525.xml  
 DAP: DIM 1: microScan3 / 0x00000001

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/> PNIO_Version	V2.41
<input checked="" type="checkbox"/> Conformance Class	C
<input checked="" type="checkbox"/> Optional Features:	Legacy, MRP
<input checked="" type="checkbox"/> Application Class	FunctionalSafety, Energy Saving
<input checked="" type="checkbox"/> Netload Class	III
<input checked="" type="checkbox"/> PNIO_Tester_Version	Version V2.43.1 with annex spirta
<input checked="" type="checkbox"/> Tester	SIEMENS AG, Fürth, Germany; PN477-6 plus Manufacturer Declaration

This certificate is granted according to the document:

“Framework for testing and certification of PROFIBUS and PROFINET products”.

For all products that are placed in circulation by **May 05, 2026** the certificate is valid for life.

Karlsruhe, July 16, 2025

Board of PROFIBUS Nutzerorganisation e. V.



(Official in Charge)



(Xaver Schmidt)




(Frank Moritz)